

From: [Halasz, Stephen \(Austin,TX-US\)](#)
To: [Gary Moore/R6/USEPA/US@EPA](#); [rbergner@rflaw.net](#)
Subject: Re: Work Plan
Date: 05/04/2011 11:54 AM

Gary,

I'm at the TCEQ trade fair and will get you an amended tomorrow that addresses all your concerns.

From: Moore.Gary@epamail.epa.gov <Moore.Gary@epamail.epa.gov>
To: Halasz, Stephen (Austin,TX-US)
Sent: Wed May 04 11:35:12 2011
Subject: Re: Work Plan

Stephen:

I am pretty much satisfied with the plan and schedule but I have the following issues:

1. How do we ensure that there is not contamination below tankage? and ensure that it gets removed?
2. How do we ensure that rainfall does not accumulate within any tankage left and not demolished? or cause a sheen within secondary containment?
3. The tankage that is left in place for the future should be inspected in accordance with industry standards: Why should a full American Petroleum Institute (API) 653 internal/external (out-of-service) inspection be conducted by a properly certified API 653 tank inspector.

We need to discuss these issues.

Thanks,
Gary Moore
Federal On-Scene Coordinator
EPA Region 6
Cell: 214-789-1627
Work: 214-665-6609
email: moore.gary@epa.gov

From: "Halasz, Stephen (Austin,TX-US)" <SHalasz@trcsolutions.com>
To: Gary Moore/R6/USEPA/US@EPA
Cc: Richard Bergner <rbergner@rflaw.net>
Date: 05/03/2011 07:24 AM
Subject: Work Plan

Gary,

Thanks for the email yesterday and the approval to proceed. Please review the attached Work Plan and let me know if this is what you're looking for. I'll be glad to make any changes.

Stephen Halasz P.G.



9567609

Program Manager



TRC Companies, Inc.

505 E. Huntland Dr.

Suite 250

Austin, Texas 78752

512-684-3351 (o)

512-745-6155 (c)

512-329-8750 fax

shalasz@trcsolutions.com

[attachment "Removal Action work to be performed FD.pdf" deleted by Gary Moore/R6/USEPA/US] [attachment "182978-RA-1.pdf" deleted by Gary Moore/R6/USEPA/US] [attachment "182978-RA-2.pdf" deleted by Gary Moore/R6/USEPA/US]